



25108 MARGUERITE PKWY. , SUITE A445
MISSION VIEJO, CA 92692

949-257-7279 FAX 949-305-1242

Project Name:	Location/ Area/ Gridlines:
Date:	Print Customer Name:
Inspected By:	Customer Signature:

STATIONARY SCAFFOLD INSPECTION CHECKLIST

	YES	NO	N/A	ACTION/COMMENTS
Does Scaffold have proper Green Tag?				
Scaffold components and planking in safe condition for use and planks graded for scaffold use?				
Is scaffold photographed?				
Frame spacing and sill size capable of carrying intended loading?				
Competent person in charge of erection and inspection?				
Sills properly placed and adequate sized?				
Screw jacks used to level and plumb scaffold?				
Base plates and/or screw jacks in firm contact with sills and frame?				
Scaffold is level and plumb?				
Scaffold legs properly braced with braces properly attached?				
Guard railing in place on all open sides and ends?				
Overhead protection or wire screening provided where necessary?				
Scaffold properly tied to structure at least every 30' in length and 26' in height?				
Brackets, tube and clamp, and accessories properly placed with nuts and bolts tightened?				
Scaffold free of makeshift devices?				
Planks have minimum 12" overlap and extend 6" beyond supports? Is the maximum spacing between planks 1"? Tripping Hazard Minimized?				
Are all platforms at least 18" wide?				
Toe boards properly installed above entrances and exits?				
Conditions such as power lines, wind loading, etc. controlled?				
Gravity Lock Pins in place for Demo Screening or Polycontainment?				
Safe access provided such as ladders or stairs above 24"? Are rest platforms provided at every 35'? Do ladders extend above platform?				
Front face within 14" of the work or within 3" for outrigger scaffolds?				